

Destinatia, aria si volumele spatiilor din cladirea "POLITIA COMUNITARA" - Str Stadionului nr.5, Pitesti

Parter	Denumire	Nr	suprafata	h	volum	incalz
	SAS 1	P01	8.98	2.96	26.6	-
	HOL ACCES	P02	32.2	2.96	95.3	i
	SALA ASTEPTARE	P03	50.78	2.96	150.3	v
	SAS 2	P04	4.81	2.96	14.2	-
	DISPECERAT	P05	22.6	2.96	66.9	v
	BIROU ARMAMANT	P06	6.7	2.96	19.8	i
	SAS + WC	P07	4	2.96	11.8	i
	BIROU 1	P08	34.4	2.96	101.8	v
	MAGAZIE	P09	34.4	2.96	101.8	i
	CABINET MEDICAL	P10	30	2.96	88.8	v
	SAS + GS	P11	4.56	2.96	13.5	i
	GS femei	P12	19.34	2.96	57.2	i
	SAS + DUS f	P13	12.2	2.96	36.1	i
	SAS b	P14	9.7	2.96	28.7	i
	GS barbati	P15	15.1	2.96	44.7	i
	DUSURI b	P16	14.8	2.96	43.8	i
	FOI PARCURS	P17	4.65	2.96	13.8	i
	CASERIE	P18	4.65	2.96	13.8	i
	CASA SCARII	P19	17.15	2.96	50.8	i
	CORIDOR	P20	50.85	2.96	150.5	i
	CAMERA CT	P21	30	2.96	88.8	i
	SAS + GS	P22	4.5	2.96	13.3	i
	SALA ANTRENAMENT	P23	68.8	2.96	203.6	v
	SALA AUDIENTE	P24	22.42	2.96	66.4	v
	HOL + ASTEPTARE	P25	11.1	2.96	32.9	i
	SALA MAT INTERVENTIE	P26	34.4	2.96	101.8	v
	SALA INSTR SCHIMBURI	P27	34.4	2.96	101.8	v
	RELATII CU PUBLICUL	P28	28.26	2.96	83.6	v
	CABINA POARTA	P29	5.33	2.96	15.8	i
	CAMERA TRAFU	P30	16.5	2.96	48.8	-
	ATELIER	P31	28.8	2.96	85.2	i
	SPALATORIE MASINI	P30	45.6	2.96	135	-
			711.98		2107.2	

ETAJ 1

Denumire	Nr	suprafata	h	volum	incalz
SECRETARIAT	101	20	2.96	59.2	v
OFICIU	102	7.4	2.96	21.9	i
GS	103	5.54	2.96	16.4	i
DIRECTOR	104	34.4	2.96	101.8	v
BIROU 2	105	34.4	2.96	101.8	v
SALA CONSILIU	106	34.4	2.96	101.8	v
BIROU 3	107	34.4	2.96	101.8	v
GS femei	108	19.34	2.96	57.2	i
SAS + DUS f	109	12.2	2.96	36.1	i
GS barbati	110	15	2.96	44.4	i
SAS + DUS b	111	9.5	2.96	28.1	i
ARHIVA	112	25	2.96	74	i
CASA SCARII	113	17.64	2.96	52.2	i
CORIDOR	114	59.06	2.96	174.8	i
ZONA GARDEROBA	115	9.5	2.96	28.1	-
OFICIU	116	24.22	2.96	71.7	i
BIROU 4	117	34.4	2.96	101.8	v
BIROU 5	118	34.4	2.96	101.8	v
BIROU 6	119	34.4	2.96	101.8	v
BIROU 7	120	34.4	2.96	101.8	v
DIRECTOR	121	34.4	2.96	101.8	v
SECRETARIAT	122	22.78	2.96	67.4	v
OFICIU	123	4.37	2.96	12.9	i
GS	124	3.08	2.96	9.1	i
DIRECTOR	125	28.25	2.96	83.6	v
CASA SCARII	126	20.69	2.96	61.2	i
SALA CONFERINTE	127	258.3	5.7	1472.3	v
LOC PENTRU FUMAT	128	10.15	2.96	30	i
		881.62		3316.8	

ETAJ 2

Denumire	Nr	suprafata	h	volum	incalz
OFITER CONTINUITATE	201	20.9	2.96	61.9	v
OFICIU	202	7.7	2.96	22.8	i
SAS + GS	203	4.7	2.96	13.9	i
BIROU 8	204	34.4	2.96	101.8	v
BIROU 9	205	34.4	2.96	101.8	v
CAMERA SERVER	206	34.4	2.96	101.8	v
BIROU 10	207	34.4	2.96	101.8	v
GS femei	208	19.34	2.96	57.2	i
SAS + DUS f	209	12.2	2.96	36.1	i
GS barbati	210	15	2.96	44.4	i
SAS + DUS b	211	9.5	2.96	28.1	i
ARHIVA	212	25	2.96	74	i
CASA SCARII	213	17.64	2.96	52.2	i
CORIDOR	214	64.23	2.96	190.1	i
CORIDOR ACC CABINE	215	11.2	2.96	33.2	i
OFICIU	216	22.3	2.96	66	i
BIROU 11	217	34.4	2.96	101.8	v
BIROU 12	218	34.4	2.96	101.8	v
BIROU 13	219	34.4	2.96	101.8	v
BIROU 14	220	34.4	2.96	101.8	v
BIROU 15	221	34.4	2.96	101.8	v
BIBLIOTECA	222	57.5	2.96	170.2	v
CASA SCARII	223	25.09	2.96	74.3	i
		621.9		1840.6	

MANSARDA

Denumire	Nr	suprafata	h	volum	incalz
GS femei	M01	13.7	2.88	39.5	i
GS barbati	M02	13.7	2.88	39.5	i
BIROU 27	M03	56	2.88	161.3	v
BIROU 28	M04	56	2.88	161.3	v
camera interventie 1	M05	20.8	2.58	53.7	v
hol	M06	4.16	2.58	10.7	-
baie	M07	4.84	2.58	12.5	-
camera interventie 2	M08	16.25	2.58	41.9	v
hol	M09	5.1	2.58	13.2	-
baie	M10	3.9	2.58	10.1	-
OFICIU	M11	19.83	2.58	51.2	v
CASA SCARII	M12	17.64	2.58	45.5	-
CIRCULATIE	M13	25.8	2.58	66.6	-
camera interventie 3	M14	20.8	2.58	53.7	v
hol	M15	6.8	2.58	17.5	-
baie	M16	4.84	2.58	12.5	-
camera interventie 4	M17	20.8	2.58	53.7	v
hol	M18	6.8	2.58	17.5	-
baie	M19	4.84	2.58	12.5	-
camera interventie 5	M20	20.8	2.58	53.7	v
hol	M21	6.8	2.58	17.5	-
baie	M22	4.84	2.58	12.5	-
SALA DE CONSILIU	M23	84.52	2.88	243.4	v
SALA DE CONSILIU	M22	43.77	2.88	126.1	v
CIRCULATIE	M23	36.1	2.88	104	-
CASA SCARII	M24	25.9	2.88	74.6	-
		545.33		1506.2	

ETAJ 3

Denumire	Nr	suprafata	h	volum	incalz
SALA PREGATIRE	301	20.9	2.96	61.9	v
OFICIU	302	7.7	2.96	22.8	i
SAS + GS	303	4.7	2.96	13.9	i
BIROU 16	304	34.4	2.96	101.8	v
BIROU 17	305	34.4	2.96	101.8	v
BIROU 18	306	34.4	2.96	101.8	v
BIROU 19	307	34.4	2.96	101.8	v
GS femei	308	19.34	2.96	57.2	i
SAS + DUS f	309	12.2	2.96	36.1	i
GS barbati	310	15	2.96	44.4	i
SAS + DUS b	311	9.5	2.96	28.1	i
BIROU 20	312	25	2.96	74	v
CASA SCARII	313	17.64	2.96	52.2	i
CORIDOR	314	62.77	2.96	185.8	i
BIROU 21	315	34.4	2.96	101.8	v
BIROU 22	316	34.4	2.96	101.8	v
BIROU 23	317	34.4	2.96	101.8	v
BIROU 24	318	34.4	2.96	101.8	v
BIROU 25	319	34.4	2.96	101.8	v
BIROU 26	320	34.4	2.96	101.8	v
SALA PREGATIRE PR	321	58	2.96	171.7	v
CASA SCARII	322	25.09	2.96	74.3	i
		621.84		1840.4	

Legenda sistem incalzire:

- "i" - numai incalzire
- "v" - incalzire iarna, racire vara si ventilare
- "-" - fara sistem de incalzire

	suprafata	volum
total	3382.67 m ²	10611.2 m ³

Destinatia, aria si volumele spatiilor din cladirea "POLITIA COMUNITARA" - Str Stadionului nr.5, Pitesti

PARTER	Denumire	Nr	suprafata	h	volum	incalz	puterea necesara (W)				corpuri incalzire statice				ventilcovectoroare			
							nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)
	SAS 1	P01	8.98	2.96	26.6	-												
	HOL ACCES	P02	32.2	2.96	95.3	-												
	SALA ASTEPTARE	P03	50.76	2.96	150.3	-	3812	3	22k-600x2000	3652	10956							
	SAS 2	P04	4.81	2.96	14.2	-	6764	1	33kx300x2000	3123	3123							
	DISPECERAT	P05	22.6	2.96	66.9	v	3211											
	BIROU ARMAMENT	P06	6.7	2.96	19.8	v	653	1	22k-600x400	730	730							
	SAS + WC	P07	3.4	2.96	10.1	v	472	1	22k-600x400	543	543							
	BIROU 1	P08	34.4	2.96	101.8	v	4581	1	22k-600x400	730	730							
	MAGAZIE	P09	34.4	2.96	101.8	v	2545	1	22k-600x1400	2556	2556							
	CABINETE MEDICAL	P10	30	2.96	88.8	v	540	1	22k-600x400	730	730							
	SAS + GS	P11	4.86	2.96	13.5	-	472	1	22k-600x400	543	543							
	ISS femei	P12	19.34	2.96	57.2	-	2288	1	22k-600x1320	2410	2410							
	SAS + DUS T	P13	12.2	2.96	36.1	-	1254	1	22k-600x720	1315	1315							
	SAS b	P14	9.7	2.96	28.7	-	861	1	22k-600x520	950	950							
	ISS barbati	P15	15.1	2.96	44.7	-	1753	1	22k-600x1000	1826	1826							
	BIROU b	P16	14.8	2.96	43.8	-	1752	1	22k-600x1000	1826	1826							
	FOI PARCURI	P17	4.85	2.96	13.8	-	414	1	22k-400x400	543	543							
	CASA SCARII	P18	17.15	2.96	50.8	-	2032	1	22k-600x2000	3652	3652							
	CORIDOR	P20	50.85	2.96	150.5	-	3010	1	22k-600x1600	2922	2922							
	CAMERA CT	P21	30	2.96	88.8	-	2042	1	22k-600x120	2045	2045							
	SAS + GS	P22	4.5	2.96	13.3	-	532	1	22k-600x400	730	730							
	SALA ANTRENAMENT	P23	68.8	2.96	203.8	v	8144											
	SALA AUDIENTE	P24	22.42	2.96	66.4	v	2988											
	HOL + ASTEPTARE	P25	11.1	2.96	32.9	-	823	1	22k-600x520	950	950							
	SALA MAT INTERVENTIE	P27	34.4	2.96	101.8	v	4581	1	22k-600x400	730	730							
	SALA INSTR SCHIMBURI	P27	34.4	2.96	101.8	v	4581	1	22k-600x400	730	730							
	RELATII CU PUBLICUL	P28	28.26	2.96	83.6	v	4013											
	CABINA POARTA	P29	5.33	2.96	15.8	-	948	1	22k-600x600	1096	1096							
	CAMERA TRAFIC	P30	16.5	2.96	48.9	-	1036											
	ATELIER	P31	28.8	2.96	85.2	-	2882	1	22k-600x1600	2922	2922							
	SPALATORIE MASINI	P30	45.6	2.96	135	-												
			711.98		2107.2					42555								36.9

ETAJ 1	Denumire	Nr	suprafata	h	volum	incalz	puterea necesara (W)				corpuri incalzire statice				ventilcovectoroare			
							nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)
	SECRETARIA	101	20	2.96	59.2	v	2368											
	OFICIU	102	7.4	2.96	21.9	v	876	1	22k-600x520	950	950							
	GS	103	5.54	2.96	16.4	-	536	1	22k-600x400	730	730							
	DIRECTOR	104	34.4	2.96	101.8	v	4581	1	22k-600x400	730	730							
	BIROU 2	105	34.4	2.96	101.8	v	4072											
	SALA CONSILIU	106	34.4	2.96	101.8	v	4276											
	BIROU 1	107	34.4	2.96	101.8	v	4072											
	ISS femei	108	19.34	2.96	57.2	-	2059	1	22k-600x1120	2045	2045							
	SAS + DUS T	109	12.2	2.96	36.1	-	1191	1	22k-600x600	1096	1096							
	ISS barbati	110	15	2.96	44.4	-	1588	1	22k-600x620	1580	1580							
	SAS + DUS b	111	9.5	2.96	28.1	-	927	1	22k-600x520	950	950							
	ARHIVA	112	25	2.96	74	-	2960	1	22k-600x1600	2922	2922							
	CASA SCARII	113	17.64	2.96	52.2	-	1566	-										
	CORIDOR	114	58.06	2.96	174.8	-	2622	1	22k-600x1400	2556	2556							
	ZONA GARDEROBA	115	9.5	2.96	28.1	-	1124											
	OFICIU	116	24.22	2.96	71.7	v	2868	1	22k-600x1600	2922	2922							
	BIROU 4	117	34.4	2.96	101.8	v	4072											
	BIROU 5	118	34.4	2.96	101.8	v	4072											
	BIROU 6	119	34.4	2.96	101.8	v	4072											
	BIROU 7	120	34.4	2.96	101.8	v	4072											
	DIRECTOR	121	34.4	2.96	101.8	v	4581	1	22k-600x400	730	730							
	SECRETARIAT	122	22.78	2.96	67.4	v	2626											
	OFICIU	123	4.37	2.96	12.9	v	516	1	22k-600x400	730	730							
	GS	124	3.08	2.96	9.1	-	364	1	22k-400x400	543	543							
	DIRECTOR	125	28.25	2.96	83.6	v	3511.2											
	CASA SCARII	126	20.69	2.96	61.1	-	1036											
	SALA CONFERINTE	127	258.3	2.96	770.7	v	70970.4											
	LOC PENTRU FUMAT	128	10.15	2.96	30	-	1560	1	22k-600x920	1580	1580							
			811.62		3316.8					15804								137.1

ETAJ 2	Denumire	Nr	suprafata	h	volum	incalz	puterea necesara (W)				corpuri incalzire statice				ventilcovectoroare			
							nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)
	OFITER CONTINUTATE	201	20.9	2.96	61.9	v	2476											
	OFICIU	202	7.7	2.96	22.8	v	912	1	22k-600x520	950	950							
	SAS + GS	203	4.7	2.96	13.9	-	504	1	22k-600x400	730	730							
	BIROU 8	204	34.4	2.96	101.8	v	4072											
	BIROU 9	205	34.4	2.96	101.8	v	4072											
	CAMERA SERVER	206	34.4	2.96	101.8	v	4072											
	BIROU 10	207	34.4	2.96	101.8	v	4072											
	ISS femei	208	19.34	2.96	57.2	-	2059.2	1	22k-600x1120	2045	2045							
	SAS + DUS T	209	12.2	2.96	36.1	-	1191.3	1	22k-600x600	1096	1096							
	ISS barbati	210	15	2.96	44.4	-	1588.1	1	22k-600x620	1580	1580							
	SAS + DUS b	211	9.5	2.96	28.1	-	927.3	1	22k-600x520	950	950							
	ARHIVA	212	25	2.96	74	-	2960	1	22k-600x1600	2922	2922							
	CASA SCARII	213	17.64	2.96	52.2	-	1566	1	22k-600x920	1580	1580							
	CORIDOR	214	64.23	2.96	191.1	-	2515	1	22k-600x1600	2922	2922							
	CORIDOR ACC CABINE	215	11.2	2.96	33.2	-	498	1	22k-600x400	730	730							
	OFICIU	216	22.3	2.96	66	v	2640	1	22k-600x1400	2556	2556							
	BIROU 11	217	34.4	2.96	101.8	v	4072											
	BIROU 12	218	34.4	2.96	101.8	v	4072											

Dimensionarea instalatiei de incalzire din cladirea "POLITIA COMUNITARA" - Str Stadionului nr.5, Pitesti

PARTER	Denumire	Nr	suprafata	h	volum	incalz	putere necesara (W)	corpuri incalzire statica			ventiloincovoare							
								nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)	Qc (kW)	total (kW)	
	HOL ACCES	P02	32.2	2.96	95.3	i	3812	3	22k-600x2000	3652	10956							
	SALA ASTEPATARE	P03	50.78	2.96	150.3	v	6763.5	1	33kx300x2000	3123	3123							
	DISPECERAT	P05	22.6	2.96	66.9	v	3211.2					1	8.UAW30.3D3	3.2	3.2	2.6	2.6	
	BIROU ARMAMANT	P06	6.7	2.96	19.8	i	653.4	1	22k-600x400	730	730							
	SAS + WC	P07	4	2.96	11.8	i	472	1	22k-600x400	730	730							
	BIROU 1	P08	34.4	2.96	101.8	v	4581					1	9.UAW30.3D3	6	6	5	5	
	MAGAZIE	P09	34.4	2.96	101.8	i	2545	1	22k-600x1400	2556	2556							
	CABINET MEDICAL	P10	30	2.96	88.8	v						1	8.UAW30.3D3	3.2	3.2	2.6	2.6	
	SAS + GS	P11	4.56	2.96	13.5	i	540	1	22k-600x400	730	730							
	GS femei	P12	19.34	2.96	57.2	i	2288	1	22k-600x1320	2410	2410							
	SAS + DUS f	P13	12.2	2.96	36.1	i	1263.5	1	22k-600x720	1315	1315							
	SAS b	P14	9.7	2.96	28.7	i	861	1	22k-600x520	950	950							
	GS barbati	P15	15.1	2.96	44.7	i	1788	1	22k-600x1000	1826	1826							
	DUSURI b	P16	14.8	2.96	43.8	i	1752	1	22k-600x1000	1826	1826							
	FOI PARCOURS	P17	4.65	2.96	13.8	i	414	1	22k-400x400	543	543							
	CASERIE	P18	4.65	2.96	13.8	i	414	1	22k-400x400	543	543							
	CASA SCARII	P19	17.15	2.96	50.8	i	2032	1	22k-600x2000	3652	3652							
	CORIDOR	P20	50.85	2.96	150.5	i	3010	1	22k-600x1600	2922	2922							
	CAMERA CT	P21	30	2.96	88.8	i	2042.4	1	22k-600x1120	2045	2045							
	SAS + GS	P22	4.5	2.96	13.3	i	532	1	22k-600x400	730	730							
	SALA ANTRENAMENT	P23	68.8	2.96	203.6	v	8144					1	10.UAW30.3D3	7.4	7.4	9.1	9.1	
	SALA AUDIENTE	P24	22.42	2.96	66.4	v	2988					1	8.UAW30.3D3	3.2	3.2	2.6	2.6	
	HOL + ASTEPATARE	P25	11.1	2.96	32.9	v	822.5	1	22k-600x520	950	950							
	SALA MAT INTERVENTIE	P26	34.4	2.96	101.8	v	4581					1	9.UAW30.3D3	6	6	5	5	
	SALA INSTR SCHIMBURI	P27	34.4	2.96	101.8	v	4581					1	9.UAW30.3D3	6	6	5	5	
	RELATII CU PUBLICUL	P28	28.26	2.96	83.6	v	4012.8					1	9.UAW30.3D3	6	6	5	5	
	CABINA POARTA	P29	5.33	2.96	15.8	i	948	1	22k-600x600	1096	1096							
	ATELIER	P31	28.8	2.96	85.2	i	2982	1	22k-600x1600	2922	2922							
			636.09		1882.6					42555				41				36.9

ETAJ 1	Denumire	Nr	suprafata	h	volum	incalz	putere necesara (W)	corpuri incalzire statica			ventiloincovoare							
								nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)	Qc (kW)	total (kW)	
	SECRETARIAT	101	20	2.96	59.2	v	2368					1	8.UAW30.3D3	3.2	3.2	2.6	2.6	
	OFICIU	102	7.4	2.96	21.9	i	876	1	22k-600x520	950	950							
	GS	103	5.54	2.96	16.4	i	656	1	22k-600x400	730	730							
	DIRECTOR	104	34.4	2.96	101.8	v	4581					1	9.UAW30.3D3	6	6	5	5	
	BIROU 2	105	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5	
	SALA CONSILIU	106	34.4	2.96	101.8	v	4275.6					1	9.UAW30.3D3	6	6	5	5	
	BIROU 3	107	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5	
	GS femei	108	19.34	2.96	57.2	i	2059.2	1	22k-600x1120	2045	2045							
	SAS + DUS f	109	12.2	2.96	36.1	i	1191.3	1	22k-600x600	1096	1096							
	GS barbati	110	15	2.96	44.4	i	1598.4	1	22k-600x920	1580	1580							
	SAS + DUS b	111	9.5	2.96	28.1	i	927.3	1	22k-600x520	950	950							
	ARHIVA	112	25	2.96	74	i	2960	1	22k-600x1600	2922	2922							
	CORIDOR	114	59.06	2.96	174.8	i	2622	1	22k-600x1400	2556	2556							
	OFICIU	116	24.22	2.96	71.7	i	2868	1	22k-600x1600	2922	2922							
	BIROU 4	117	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5	
	BIROU 5	118	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5	
	BIROU 6	119	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5	
	BIROU 7	120	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5	
	DIRECTOR	121	34.4	2.96	101.8	v	4581					1	9.UAW30.3D3	6	6	5	5	
	SECRETARIAT	122	22.78	2.96	67.4	v	2696					1	8.UAW30.3D3	3.2	3.2	2.6	2.6	
	OFICIU	123	4.37	2.96	12.9	i	516	1	22k-600x400	730	730							
	GS	124	3.08	2.96	9.1	i	364	1	22k-400x400	543	543							
	DIRECTOR	125	28.25	2.96	83.6	v	3511.2					1	9.UAW30.3D3	6	6	5	5	
	SALA CONFERINTE	127	258.3	5.7	1472.3	v	70670.4					9	10.UAW30.3D3	8.2	73.8	9.1	81.9	
	LOC PENTRU FUMAT	128	10.15	2.96	30	i	1560	1	22k-600x920	1580	1580							
			833.79		3175.3					18604				140.2				137.1

ETAJ 2	Denumire	Nr	suprafata	h	volum	incalz	putere necesara (W)	corpuri incalzire statica			ventiloincovoare						
								nr buc	tip	Qh (kW)	total (kW)	nr buc	tip	Qh (kW)	total (kW)	Qc (kW)	total (kW)
	OFFICER CONTINUITATE	201	20.9	2.96	61.9	v	2476					1	8.UAW30.3D3	3.2	3.2	2.6	2.6
	OFICIU	202	7.7	2.96	22.8	i	912	1	22k-600x520	950	950						
	SAS + GS	203	4.7	2.96	13.9	i	500.4	1	22k-600x400	730	730						
	BIROU 8	204	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	BIROU 9	205	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	CAMERA SERVER	206	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	BIROU 10	207	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	GS femei	208	19.34	2.96	57.2	i	2059.2	1	22k-600x1120	2045	2045						
	SAS + DUS f	209	12.2	2.96	36.1	i	1191.3	1	22k-600x600	1096	1096						
	GS barbati	210	15	2.96	44.4	i	1598.4	1	22k-600x920	1580	1580						
	SAS + DUS b	211	9.5	2.96	28.1	i	927.3	1	22k-600x520	950	950						
	ARHIVA	212	25	2.96	74	i	2960	1	22k-600x1600	2922	2922						
	CASA SCARII	213	17.64	2.96	52.2	i	1566	1	22k-600x920	1580	1580						
	CORIDOR	214	64.23	2.96	190.1	i	2851.5	1	22k-600x1600	2922	2922						
	CORIDOR ACC CABINE	215	11.2	2.96	33.2	i	498	1	22k-600x400	730	730						
	OFICIU	216	22.3	2.96	66	i	2640	1	22k-600x1400	2556	2556						
	BIROU 11	217	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	BIROU 12	218	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	BIROU 13	219	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	BIROU 14	220	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	BIROU 15	221	34.4	2.96	101.8	v	4072					1	9.UAW30.3D3	6	6	5	5
	BIBLIOTECA																

DIMENSIONARE NECESARUL DE AER
SI GURILE DE ASPIRATIE SI REFULARE

	A camera	h	v (mc)	nr sch aer proaspat	nec aer proaspat	incalz	nr recirculari	aer recirculat	viteza m/s	A (mp)	tip gura refulare	tip gura absorbtie	A ef	raport	nr. necesar	UM
PARTER																
HOL ACCES	32.2	2.96	95.3			/										
SALA ASTEPTARE	50.78	2.96	150.3	0.8	120	v	6	901.8	2.5	0.013	CRL 125		0.02	0.667	1	buc
DISPECERAT	22.6	2.96	66.9			v										
BIROU ARMAMENT	6.7	2.96	19.8			/										
SAS + WC	4	2.96	11.8			/										
BIROU 1	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
MAGAZIE	34.4	2.96	101.8			/										
CABINET MEDICAL	30	2.96	88.8	0.8	71	v	6	532.8	2.5	0.008	CRL 125		0.02	0.394	2	buc
SAS + GS	4.56	2.96	13.5			/										
GS femei	19.34	2.96	57.2	1	57	/	6	343.2	5	0.003		AVR-R 350	0.03	0.113	1	buc
SAS + DUS f	12.2	2.96	36.1			/										
SAS b	9.7	2.96	28.7			/										
GS barbati	15.1	2.96	44.7	1	45	/	6	268.2	5	0.003		AVR-R 350	0.03	0.089	1	buc
DUSURTI b	14.8	2.96	43.8			/										
FOI PARCURS	4.65	2.96	13.8			/										
CASERIE	4.65	2.96	13.8			/										
CASA SCARII	17.15	2.96	50.8			/										
CORIDOR	50.85	2.96	150.5	0.6	90	/			2.5	0.010						
CAMERA CT	30	2.96	88.8			/										
SAS + GS	4.5	2.96	13.3			/										
SALA ANTRENAMENT	68.8	2.96	203.6	0.8	163	v	8	1628.8	2.5	0.018	CRL 160		0.03	0.647	2	buc
SALA AUDIENTE	22.42	2.96	66.4	0.8	53	v	6	398.4	2.5	0.006	CRL 160		0.03	0.210	1	buc
HOL + ASTEPTARE	11.1	2.96	32.9			/										
SALA MAT INTERVENTIE	34.4	2.96	101.8	0.6	61	v	6	610.8	2.5	0.007	CRL 160		0.03	0.242	2	buc
SALA INSTR SCHIMBUR	34.4	2.96	101.8	0.6	61	v	6	610.8	2.5	0.007	CRL 160		0.03	0.242	2	buc
RELATII CU PUBLICUL	28.26	2.96	83.6	0.8	67	v	8	668.8	2.5	0.007	CRL 125		0.02	0.372	2	buc
CABINA POARTA	5.33	2.96	15.8			/										
ATELIER	28.8	2.96	85.2			/										
ETAJ 1																
SECRETARIAT	20	2.96	59.2	0.8	47	v	6	355.2	2.5	0.005	CRL 125		0.02	0.261	2	buc
OFICIU	7.4	2.96	21.9			/										
GS	5.64	2.96	16.4			/										
DIRECTOR	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 2	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
SALA CONSILIU	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 3	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
GS femei	19.34	2.96	57.2	1	57	/	8	457.6	5	0.003		AVR-R 350	0.03	0.113	1	buc
SAS + DUS f	12.2	2.96	36.1			/										
GS barbati	15	2.96	44.4	1	44	/	8	355.2	5	0.002		AVR-R 350	0.03	0.087	1	buc
SAS + DUS b	9.5	2.96	28.1			/										
ARHIVA	25	2.96	74			/										
CORIDOR	59.06	2.96	174.8	0.6	105	/			2.5	0.012						
OFICIU	24.22	2.96	71.7			/										
BIROU 4	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 5	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 6	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 7	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
DIRECTOR	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
SECRETARIAT	22.78	2.96	67.4	0.8	54	v	6	404.4	2.5	0.006	CRL 125		0.02	0.300	2	buc
OFICIU	4.37	2.96	12.9			/										
GS	3.08	2.96	9.1			/										
DIRECTOR	28.25	2.96	83.6	0.8	67	v	6	501.6	2.5	0.007	CRL 125		0.02	0.372	2	buc
SALA CONFERINTA	258.3	5.7	1472.3	0.8	1178	v	6	8833.8	2.5	0.131	CRL 125		0.02	6.544	9	buc
LOC PENTRU FUMAT	10.15	2.96	30			/										
ETAJ 2																
OFITER CONTINUTATE	20.9	2.96	61.9	0.8	50	v	6	371.4	2.5	0.006	CRL 125		0.02	0.278	2	buc
OFICIU	7.7	2.96	22.8			/										
SAS + GS	4.7	2.96	13.9			/										
BIROU 8	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 9	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
CAMERA SERVER	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 10	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
GS femei	19.34	2.96	57.2	1	57	/	8	457.6	5	0.003		AVR-R 350	0.03	0.113	1	buc
SAS + DUS f	12.2	2.96	36.1			/										
GS barbati	15	2.96	44.4	1	44	/	8	355.2	5	0.002		AVR-R 350	0.03	0.087	1	buc
SAS + DUS b	9.5	2.96	28.1			/										
ARHIVA	25	2.96	74			/										
CASA SCARII	17.64	2.96	52.2			/										
CORIDOR	64.23	2.96	190.1			/										
CORIDOR ACC CABINE	11.2	2.96	33.2			/										
OFICIU	22.3	2.96	66			/										
BIROU 11	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 12	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 13	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 14	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 15	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIBLIOTECA	57.5	2.96	170.2	0.8	136	v	6	1021.2	2.5	0.015	CRL 160		0.03	0.540	3	buc
CASA SCARII	25.09	2.96	74.3			/										
ETAJ 3																
SALA PREGATIRE	20.9	2.96	61.9	0.8	50	v	6	371.4	2.5	0.006	CRL 125		0.02	0.278	2	buc
OFICIU	7.7	2.96	22.8			/										
SAS + GS	4.7	2.96	13.9			/										
BIROU 16	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 17	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 18	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 19	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
GS femei	19.34	2.96	57.2	1	57	/	8	457.6	5	0.003		AVR-R 350	0.03	0.113	1	buc
SAS + DUS f	12.2	2.96	36.1			/										
GS barbati	15	2.96	44.4	1	44	/	8	355.2	5	0.002		AVR-R 350	0.03	0.087	1	buc
SAS + DUS b	9.5	2.96	28.1			/										
BIROU 20	25	2.96	74	0.8	59	v	6	444	2.5	0.007	CRL 125		0.02	0.328	2	buc
CASA SCARII	17.64	2.96	52.2			/										
CORIDOR	62.77	2.96	185.8			/										
BIROU 21	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 22	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 23	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 24	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 25	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
BIROU 26	34.4	2.96	101.8	0.8	81	v	6	610.8	2.5	0.009	CRL 125		0.02	0.450	2	buc
SALA PREGATIRE PR	58	2.96	171.7	0.8	137	v	6	1030.2	2.5	0.015	CRL 160		0.03	0.544	3	buc
MANSARDA																
GS femei	13.7	2.88	39.5	1	40	/	8	316	5	0.002		AVR-R 350	0.03	0.079	1	buc
GS barbati	13.7	2.88	39.5	1	40	/	8	316	5	0.002		AVR-R 350	0.03	0.079	1	buc
BIROU 27	56	2.88	161.3	0.8	129	v	6	967.8	2							

DIMENSIONARE
SECTIUNE DE TRECERE PENTRU CANALE DE VENTILATIE

Tronson	nec aer proaspat		lungimea m	viteza m/s	sectiune canal mp	dimensiune canal a x b (mm)	sectiune echivalent mp	R mm H ₂ O/m	R x l	sum (psi)	v ² x(ro)/2g	Z	(Rl+Z)	sum(Rl+Z)
	mc/h	mc/s												
PARTER														
SALA ASTEPTARE	120	0.03	5	6	0.006	100x100	0.01							
RELATII CU PUBLICUL	67	0.02	4	6	0.003	100x100	0.01							
dispecerat si relatii cu public	187	0.05	11	8	0.007	100x100	0.01							
SALA ASTEPTARE	120	0.03	5	6	0.006	100x100	0.01							
SALA INSTR SCHIMBURI	61	0.02	5	6	0.003	100x100	0.01							
cale comuna	368	0.1	5	9	0.012	100x100	0.01							
BIROU 1	81	0.02	5	6	0.004	100x100	0.01							
SALA MAT INTERVENTIE	61	0.02	5	6	0.003	100x100	0.01							
cale comuna	510	0.14	5	9	0.017	100x150	0.02							
CABINET MEDICAL	71	0.02	5	6	0.004	100x100	0.01							
SALA AUDIENTE	53	0.02	5	6	0.003	100x100	0.01							
cale comuna	634	0.18	10	9	0.021	150x150	0.02							
SALA ANTRENAMENT	163	0.05	5	6	0.008	100x100	0.01							
cale comuna parter	797	0.22	7	11	0.021	150x150	0.02							
ETAJ 1														
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	4	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	9	#REF!	100x150	0.02							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	9	#REF!	150x150	0.02							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	10	#REF!	150x150	0.02							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	10	#REF!	200x150	0.03							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	10	#REF!	200x150	0.03							
#REF!	#REF!	#REF!	24	6	#REF!	100x150	0.02							
#REF!	#REF!	#REF!	4	7	#REF!	150x150	0.02							
#REF!	#REF!	#REF!	4	8	#REF!	250x200	0.05							
cale comuna etaj 1	#REF!	#REF!	3	10	#REF!	300x250	0.08							
cale comuna parter - etaj 1	#REF!	#REF!	3	11	#REF!	300x250	0.08							
cale comuna CTA	#REF!	#REF!	16	12	#REF!	400x350	0.14							
ETAJ 2														
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	100x150	0.02							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	150x150	0.02							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	150x150	0.02							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	200x150	0.03							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	200x150	0.03							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna etaj 2	#REF!	#REF!	4	10	#REF!	200x150	0.03							
cale comuna etaj 2; 3; M	#REF!	#REF!	3	12	#REF!	300x250	0.08							
ETAJ 3														
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	100x150	0.02							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	150x150	0.02							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	200x150	0.03							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	8	#REF!	200x150	0.03							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna	#REF!	#REF!	5	9	#REF!	200x150	0.03							
#REF!	#REF!	#REF!	5	6	#REF!	100x100	0.01							
cale comuna etaj 3	#REF!	#REF!	4	10	#REF!	200x150	0.03							
cale comuna etaj 3; M	#REF!	#REF!	3	12	#REF!	200x250	0.05							
MANSARDA														
#REF!	135	0.08	14	6	0.014	200x100	0.02							
#REF!	163	0.05	5	6	0.008	100x100	0.01							
cale comuna	298	0.08	5	8	0.011	200x100	0.02							
#REF!	246	0.07	15	6	0.012	100x150	0.02							
cale comuna	544	0.15	10	8	0.020	200x100	0.02							
#REF!	163	0.05	6	6	0.008	100x100	0.01							
cale comuna	707	0.2	5	8	0.026	200x150	0.03							
#REF!	36	0.01	6	6	0.002	100x100	0.01							
#REF!	36	0.01	6	6	0.002	100x100	0.01							
cale comuna	779	0.22	5	9	0.025	200x150	0.03							
#REF!	28	0.01	6	6	0.001	100x100	0.01							
#REF!	36	0.01	6	6	0.002	100x100	0.01							
cale comuna	843	0.23	5	9	0.027	200x150	0.03							
#REF!	28	0.01	6	6	0.001	100x100	0.01							
#REF!	36	0.02	6	6	0.003	100x100	0.01							
cale comuna mansarda	907	0.25	3	10	0.027	200x150	0.03							